



EC declaration of conformity					
For the following equipment:					
Product Name: Switching Power Supplies					
Model Designation: CEN-X-Y (X=60 or 75; Y=12,15,20,24,30,36,42,48,54; Y=12 only for CEN-60)					
is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :					
RoHS Directive (201	1/65/EU)				
Energy-Related Products Directive (2009/125/EC) Implementing measure COMMISSION REGULATION(EC) No 1194/2012					
Low Voltage Directive (2006/95/EC):					
EN61347-1:2008+A1+A2/ EN61347-2-13:2006 TUV certificate No : R5018				R50181371	
Electromagnetic Compatibility Directive (2004/108/EC):					
EMI (Electro-Magnetic Interference)					
Conducted emission / Radiated emission					
	EN55015:2006+A1:2007+A2	:2009			
Harmonic current	EN61000-3-2:2006+A1:2009	+A2:2009		class	C(≧75% load)
Voltage flicker	EN61000-3-3: 2008				
EMS (Electro-Magnetic	Susceptibility)				
EN61547:2009					
ESD air	EN61000-4-2:2009		Level 3	8KV	
ESD contact	EN61000-4-2:2009		Level 2	4KV	
RF field susceptibility	EN61000-4-3:2006+A1:2008	+A2:2010	Level 2	3V/m	
EFT bursts	EN61000-4-4:2012		Level 2	1KV/5KHz	
Surge susceptibility Conducted	EN61000-4-5:2006		Level 4	2KV/Line-Line	4KV/Line-Earth
susceptibility	EN61000-4-6:2009		Level 2	3V	
Magnetic field immunity	EN61000-4-8:12010		Level 2	3A/m	
Voltage dip, interruption EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods Note: Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. Tests above are only to be performed with LEDs. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).					
To fulfill requirements of the latest ErP regulation for lighting fixtures, this LED power supply can only be used behind a switch without permanently connected to the mains.					
This Declaration is effective from serial number HB4xxxxxxx					
Person responsible for marking this declaration :					
Mean Well Enterprises C (Manufacturer Name)	o., Ltd.				
No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan (R.O.C.) (Manufacturer Address)					
Johnny Huang/Senior Verification Engineer: (Name / Position) Ted Cheng/Product Manager: (Name / Position) (Signature) (Signature)					

Jun. 17th, 2014

(Date)

Taiwan

(Place)