



## Declaration of Conformity

For the following equipment :

**Product Name:** Surge Protection Device

**Model Designation:** SPD-20-240P

**Identification:**

Max. Continuous operating voltage(Uc):	AC300V
Voltage protection Level(Up):	1500V
Test Class:	II
Nominal Discharge Current(In):	5KA
Max. discharge Current(I <sub>max</sub> ):	20KA
Protection Degree:	IP67
Location Category:	Indoor
Temperature Range:	-40°C to +70°C

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

**RoHS Directive (2011/65/EC)**

**Low Voltage Directive (2006/95/EC) :**

EN61643-11: 2002+A11

TUV certificate No : AK502499110001

**Note:**

This Declaration is effective from serial number HB3xxxxxxx

Person responsible for marking this declaration :

**Mean Well (Guangzhou) Electronics Co., Ltd.**

(Manufacturer Name)

2<sup>nd</sup> Floor, NO.A Building, Yuean Industrial Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou City, China  
(Manufacturer Address)

Howay\_Lin/ Engineering Manager : *Howay Lin*  
(Name / Position) (Signature)

Frank\_Peng/RD Manager : *Frank Peng*  
(Name / Position) (Signature)

GuangZhou  
(Place)

Mar. 15. 2013  
(Date)