



## **Declaration of conformity**

For the following equipment:

Product Name: LED Driver

Model Designation: IDLC-45x-yz (x=A or Blank; y=350,500,700,1050,1400;z=DA or Blank)

IDLC-65x-yz (x=A or Blank; y=700,1050,1400,1750;z=DA or Blank) ODLC-45x-yz (x=A or Blank; y=350,500,700,1050,1400;z=DA or Blank) ODLC-65x-yz (x=A or Blank; y=700,1050,1400,1750;z=DA or Blank)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

RoHS Directive (2011/65/EU)、(EU)2015/863

Energy-Related Products Directive (2009/125/EC) Implementing measure COMMISSION REGULATION(EC) No 1194/2012

Low Voltage Directive (2014/35/EU):

EN 61347-1:2015 EN61347-2-13:2014/A1:2017

EN 62384: 2006/A1:2009 ENEC certificate No: 35-103782

## Electromagnetic Compatibility Directive (2014/30/EU):

## **EMI (Electro-Magnetic Interference)**

Conducted emission / Radiated emission

EN55015:2013+A1:2015

Harmonic current	EN61000-3-2:2014		Class C(≥50% load)	
Voltage flicker	EN61000-3-3:2013			
EMS (Electro-Magnetic S	Susceptibility)			
EN61547:2009				
ESD air	EN61000-4-2:2009	Level 3	8KV	
ESD contact	EN61000-4-2:2009	Level 2	4KV	
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 2	3V/m	
EFT bursts	EN61000-4-4:2012	Level 2	1KV/5KHz	
Surgo susceptibility	EN61000 4 5:2014	Lovol 2	1KV/(Line Line)	

Surge susceptibility	EN61000-4-5:2014		Level 3	1KV (Line-Line
Conducted susceptibility	EN61000-4-6:2014		Level 2	3V
Magnetic field immunity	EN61000-4-8:2010		Level 2	3A/m
Voltage dip, interruption	EN61000-4-11:2004	30% dip 10 periods	100% interruptions 0.5 periods	
				•

Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number HB9xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification Center:

(Name / Position)

(Name / Position) (Signature)

Alex Tsai/Director, Marketing Department:

Taiwan

Jul. 22nd, 2019

(Date)

(Place)

Version: 3